

C.NO/128/ADV/DFO/VJP/2024

23/09/2024

To,
The Prsident
B.L.D.E Associations Vijayapur,
B.M. Patil Road, Vijayapur City
Vijayapur Taluk, Vijayapur District

Sir,

Sub : Issue of 'Fire safety recommendation/Advice' to B.L.D.E Associations
Vijayapur, Sri B.M. Patil Public School at Sy No : 142, B.M. Patil Road,
Vijayapur City, Vijayapur Taluk, Vijayapur District.

Ref: 1) Applicant request letter Dated 17/09/2024.
2) No.GBC(2)044/2020-21 Dated 18/06/2022 S.O No.156-B.
3) C.No : 34/SCHOOL ADV/FSO/INDI/2024. Dated : 17/09/2024.

**_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of B.L.D.E Associations
Vijayapur, Sri B.M. Patil Public School, 02 Blocks/ Building consisting with Block 'A' &
Block 'B' Building Ground floor + 02 Upper floors situated at Sy No : 142, B.M. Patil
Road, Vijayapur City, Vijayapur Taluk, Vijayapur District. Was inspected by Fire Station
Officer Vijayapur on 12/09/2024 with respect to Fire prevention, Fire fighting and Evacuation
measures to be complied in the above premises and has submitted the details as under with
reference cited (3).

ANNEXURE-1

(Up to 14.99 mtrs. in height)
Group B Education Building

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings sub division B1 & B2.
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety
of NBC 2016 are mandatory)

A. Details of the building / premises :-


| | | | |
|----|------------------------------------|---|---|
| 01 | Name and Address of the Applicant. | : | The Prsident B.L.D.E Associations Vijayapur, B.M. Patil Road, Vijayapur City Vijayapur Taluk, Vijayapur District |
| 02 | Name and Address of the premises | : | Sri B.M. Patil Public School at Sy No : 142, B.M. Patil Road, Vijayapur City, Vijayapur Taluk, Vijayapur District |



clause 3.1.4 of Fire and Life safety will have to be complied with mandatorily.

From the above details it is clear that the 'Management' of the above Educational building have been recommended to provide fire precautionary measures as per National Building Code 2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2. After full-filling the above recommendations, a Certificate should be obtained by this office. *If at any time any of the conditions are found not complied with, this Certificate shall stand withdrawn/cancelled.*

The Fire Safety Recommendation is valid for a period of one year from the date of issue and it is renewable.



Fire Station Officer Vijayapur.

Yours faithfully
[Signature]
DISTRICT FIRE OFFICER
VIJAYAPUR-586108